

TYPE APPROVAL CERTIFICATE

This is to certify:**That the Pressure Switch**with type designation(s)
EPN-S 8320

Issued to

Trafag AG
Bubikon, ZH, Switzerland

is found to comply with

DNV GL rules for classification – Ships, offshore units, and high speed and light craft**Application :****Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.****Location classes:**

Temperature	D (extended test -40°C to +125°C)
Humidity	B
Vibration	B (extended test 15g from 50 Hz to 2000 Hz)
EMC	B
Enclosure	B / IP65

Issued at **Høvik** on **2017-12-15**for **DNV GL**This Certificate is valid until **2022-10-30**.DNV GL local station: **Augsburg**Approval Engineer: **Ståle Sneen****Odd Magne Nesvåg**
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



Product description

Electronic pressure switch model EPN-S 8320.
Sensor: Thin film on steel
Measuring range: 0...2.5 bar to 0...600 bar
Pressure connection: G1/2" or G1/4"
Electrical connection: connector EN 175301-803-A (DIN43650-A)
Power supply: 24 VDC
Output: 1 x transistor (open source)

Approval conditions

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL rules for classification of ships Pt.4 Ch.9 Control and monitoring systems.

Application/Limitation

Shielded cable is required.

Type Approval documentation

Test Reports: TRAFAG No. V-11135 (2012-03-13), No. V-12078 (2012-10-18),
EMC-Testcenter Zürich No. EMCKP1904A (2011-11-23)
Drawings: C20101(b), B63290(d)
Data sheet: H72333g
Type approval renewal assessment report for 47216-12HH, DNV GL Augsburg 2017-12-14

Tests carried out

Applicable tests according to class guideline DNVGL-CG-0339, November 2016.
Extended 'Vibration Test': 15g (50...2000 Hz)
Extended 'Dry Heat Test': +125°C
Extended 'Cold Test': -40°C

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number
- power supply ratings

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE